



Ref. Certif. No.

SE-113228

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Extension module

Name and address of the applicant

Loxone Electronics GmbH
Smart Home 1
AT-4154 Kollerschlag
AUSTRIA

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Additional Information on page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

20-28Vdc, 2.9W

Trademark / Brand (if any)

Loxone

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

M-Bus Extension

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62368-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

2251481KAU-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Date: 19 February, 2024

intertek

Signature:

Anneli Averland Johansson

Factories

[Redacted]

[Redacted]

[Redacted]

Additional information

General product information and other remarks:

The Loxone M-Bus Extension is a M-Bus master for DIN rail mounting for reading up to 30 M-Bus devices like gas-, water-, or energy meters. The read out values can be used for energy management, consumption data collection and much more.

Conditions of Acceptability

1. Suitability of the enclosure should be evaluated when installed in the end product.
2. Temperature Testing should be performed on this component when installed in the end product.
3. The device shall be supplied with a ES1 (SELV) and PS2 (LPS) power supply. General product information and other remarks:

Date: 19 February, 2024

Signature:

